



NOTES:

1. SOLVENT WELD ALL JOINTS (NON GASKETED).
2. IN ALL CASES, INSTALL A 6" HEAVY METAL TEE POST 3' ABOVE FINISHED GRADE AND PAINT THE TOP 6" OF POST FLUORESCENT GREEN. OVERLAP METAL TEE POST 1' WITH 2"x2" WOOD MARKER POST.
3. THE USE OF BENDS SHALL BE RESTRICTED TO THE TWO SHOWN ON THIS DETAIL.
4. ANY REQUIRED CLEANOUTS SHALL NOT BE LOCATED WITHIN THE PUBLIC RIGHT-OF-WAY.
5. WHEN DEPTH IS GREATER THAN 26' C-900 PIPE SHALL BE USED FOR SANITARY SEWER MAINLINES AND RISERS.
6. ALL PIPE SHALL BE BEDDED ON GRANULAR BEDDING (MNDOT 3149.2-F) OR COURSE FILTER AGGREGATE (MNDOT 3149.2-H).
7. INSTALL TRACER WIRE SYSTEM AS PER SPEC'S AND DETAIL PLATE 5507.
8. WHEN A SIDEWALK OR TRAIL IS PRESENT IN THE BLVD. THE SERVICE MAY BE EXTENDED INTO THE D&U EASEMENT WITH THE CITY ENGINEERS APPROVAL.



TYPICAL SANITARY SERVICE RISER (GREATER THAN 16' DEEP)

REVISED: 2-24

ENGINEERING DEPARTMENT

PLATE NO.:

2002