


NOTES:

1. KOR-N-SEAL MANHOLE OR EQUAL CONSIDERED ACCEPTABLE ALTERNATE.
2. ALL DOG HOUSES SHALL BE GROUTED ON INSIDE.
3. WHEN THE MANHOLE STRUCTURE IS CONSTRUCTED OUTSIDE THE TRAVELED ROADWAY A WITNESS POST AND SIGN (MH) SHALL BE INSTALLED NEXT TO THE MANHOLE CENTERED BEHIND THE STRUCTURE FROM THE ROADWAY.
4. STEPS SHALL BE ON THE UPSTREAM SIDE ONLY IF THE MANHOLE IS A DEAD-END MANHOLE.
5. STEPS SHALL BE INSTALLED ON EITHER SIDE OF THE DOWNSTREAM PIPE INVERT IF THE PIPE DIAMETER IS 18" OR LARGER.

 EACH STRUCTURE SHALL BE CHECKED FOR BUOYANCY AND CERTIFIED BY THE ENGINEER OF RECORD THAT FLOTATION WILL NOT OCCUR.



STANDARD SANITARY SEWER MANHOLE

REVISED: 2-24

ENGINEERING DEPARTMENT

PLATE NO.:

2101