




-  Compacted native fill material/95% proctor
-  MNDOT 3149.2B
-  MNDOT 3149.2H

NOTES:

1. A soils Engineer will be required to determine the depth of the pipe foundation embedment material if needed. Pipe foundation material shall be in accordance with MNDOT 3149.2H course filter aggregate.
2. P.V.C. bedding shall be MNDOT 3149.2B select granular borrow with 100% passing a 3/4" sieve, and less than 10% passing a NO. 200 sieve.
3. Trench slopes shall conform to current OSHA rules and regulations for excavations and trenches.



**CITY OF
CHANHASSEN**

PIPE BEDDING
FOR P.V.C. PIPE

REVISED: 11-19

FILE NAME: G:\ENG\SPECS\2203

ENGINEERING DEPARTMENT

PLATE NO.:

2203