


SECTION VIEW

THE MINIMUM THICKNESS FOR THE PRECAST BASE SHALL BE IN ACCORDANCE WITH DETAIL PLATE 2100.

NOTES:

1. ALL DOG HOUSES SHALL BE GROUTED BOTH INSIDE AND OUTSIDE OF THE STRUCTURE.
2. WHEN THE MANHOLE OR CATCH BASIN STRUCTURE IS CONSTRUCTED OUTSIDE OF THE TRAVELED ROADWAY A WITNESS POST AND SIGN (MH) SHALL BE INSTALLED BEHIND THE MH.
3. IF A SUMP MH IS REQUIRED, A MINIMUM SUMP DEPTH OF 4' SHALL BE CONSTRUCTED BELOW THE LOWEST PIPE INVERT IN THE STRUCTURE.

	EACH STRUCTURE SHALL BE CHECKED FOR BUOYANCY AND CERTIFIED BY THE ENGINEER OF RECORD THAT FLOTATION WILL NOT OCCUR.
-------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------



STANDARD STORM MANHOLE

REVISED: 2-24

ENGINEERING DEPARTMENT

PLATE NO.:

3100