

- 3. MINIMUM STREET GRADE 0.75%.
- 4. 6" TOPSOIL PLACED IN DISTURBED AREAS.
- 5. THE BITUMINOUS WEARING SURFACE SHALL BE PLACED THE NEXT CONSTRUCTION SEASON FOLLOWING PLACEMENT OF THE BITUMINOUS BASE.
- 6. A TEST ROLL OF THE PREPARED SUBGRADE AND AGGREGATE BASE SHALL BE PERFORMED IN THE PRESENCE OF A CITY INSPECTOR. THE CITY HAS THE AUTHORITY TO REQUIRE ADDITIONAL SUBGRADE CORRECTION BASED ON THE TEST ROLL.
- 7. DRAINTILE SHALL BE PLACED ALONG BOTH SIDES OF ROADWAY. SEE DETAIL PLATE 5232 OR 5232A.
- 8. SMALL UTILITIES TO BE PLACED WITHIN THE PUBLIC DRAINAGE AND UTILITY EASEMENT (DUE).



TYPICAL COMMERCIAL/INDUSTRIAL STREET SECTION

REVISED: 2-24

PLATE NO.:

5201