

NOTE:

- 1. Use #4 (1/2) rebar slab reinforcement in R.O.W placed @ 6" in from each edge. Rebar is to be spaced 2' on centers, being 6" on center in the gutter.
- 2. Contraction joints shall be 1/3 the depth of the slab.
- 3. Maximum pavement slope allowed within 30' of the street is 4.5%.
- 4. All concrete mixes shall be as shown in Chanhassen Street Construction Specification under section 4.05.
- 5. If the water shutoff is located in the driveway pavement a cover as manufactured by Mcdonald 74M1A series with an 8" frame & cover or equal shall be installed.
- 6. MnDot B618 or B612 curbs must be poured monolithically with driveways,
- 7. Sidewalks shall take grade precedence through driveways.



COMMERCIAL/INDUSTRIAL
CONCRETE DRIVEWAY APRON

REVISED: 2-22

FILE NAME: G: \ENG\SPECS\5207

ENGINEERING DEPARTMENT

PLATE NO.:

5207