



1. Thrust blocking may be a Mega lug cap or plug with 304 stainless steel or Cor-Blue bolts, nuts and washers. Tie back to the previous joint is required.
2. Once the test requirements have been met the air bleed line, (if installed) shall be disconnected at the plug with no additional compensation.

Note:

A water service tap or nearby hydrant may be used to bleed air out of the line, if approved by the engineer.



**CITY OF
CHANHASSEN**

AIR
BLEED
DETAIL

REVISED: 3-23

FILE NAME: G:\ENG\SPECS\1003

ENGINEERING DEPARTMENT

PLATE NO.:

1003