



**NOTES:**

1. DO NOT PLUG END OF CURB STOP.
2. FOR COPPER TUBING ADD 6" CRIMPED PIGTAIL TO CURB STOP, IF PLASTIC SERVICE USE END CAP/PLUG OR BEND PIPE OVER AND TAPE END.
3. THE SERVICE LINE BETWEEN THE MAIN SHUTOFF CORP. AND CURB BOX SHALL BE ONE CONTINUOUS SEAMLESS PIECE OF PIPE, COUPLERS WILL NOT BE PERMITTED
4. CORPORATION COCK TO BE OF THE QUICK COMPRESSION TYPE AS STATED IN SECTION 2.11 OF THE WATERMAIN SPECIFICATIONS.
5. ALL TAPS REQUIRE USE OF STAINLESS STEEL SADDLES ON ALL MAINS.
6. SADDLES SHALL BE SMITH BLAIR 372 OR APPROVED EQUAL AS PER SECTION 2.14 OF THE WATERMAIN SPECIFICATIONS.
7. INSTALL TRACER WIRE SYSTEM AS PER DETAIL PLATE 5504.



## TYPICAL WATER SERVICE

REVISED: 2-24

ENGINEERING DEPARTMENT

PLATE NO.:

**1005**