



NOTES:

1. D.I.P. CONDUCTIVITY SHALL BE PROVIDED THROUGHOUT THE WATER SYSTEM BY USE OF COPPER STRAPS OR APPROVED CONDUCTIVE GASKETS WITH COPPER INSERTS.
2. ALL JOINTS AND FITTINGS SHALL BE CONNECTED WITH AN ELECTRICAL CONDUCTING COPPER STRAP, CLIPS OR CABLE DESIGNED AND TESTED TO WITHSTAND 400 AMPS. ALL MECHANICAL JOINT FITTINGS SHALL BE EQUIPPED WITH COPPER STRAPS. LEAD TIPPED GASKETS WILL NOT BE APPROVED FOR CONDUCTIVITY.
3. CONDUCTIVITY STRAPS SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS.
4. FOR LOCATIONS WHERE SHOP WELDED STRAPS ARE NOT AVAILABLE, CONSULT THE ENGINEER FOR AN APPROVED ALTERNATE METHOD OF CONDUCTIVITY IN ACCORDANCE WITH WATERMAIN SPECIFICATION SECTION 8.05.



D.I.P. CONDUCTIVITY

REVISED: 2-24

ENGINEERING DEPARTMENT

PLATE NO.:

1012