



NOTES:

1. ON BITUMINOUS STREETS, CONTRACTOR SHALL SAWCUT AND REPLACE MINIMUM 18" WIDE STRIP OF THE WEAR PAVEMENT LAYER. REPLACE BITUMINOUS WITH SAME PAVEMENT TYPE TO MATCH EXISTING STREET SECTION. APPLY TACK COAT TO EXISTING PAVEMENT SURFACES/EDGES PRIOR TO PLACING NEW WEAR LAYER.
2. FOR AREA OF DRIVEWAY LOCATED WITHIN THE R.O.W., DRIVEWAY PAVEMENT THICKNESS SHALL BE A MINIMUM OF 2-2" LIFTS OF BITUMINOUS WITH 6" OF CLASS 5 AGGREGATE BASE.
3. IF WATER SHUTOFF IS IN THE DRIVEWAY PAVEMENT, A COVER AS MANUFACTURED BY MCDONALD 74M1A SERIES WITH AN 8" OPENING FRAME AND COVER OR APPROVED EQUAL SHALL BE INSTALLED.
4. IF RADIUS IS INSTALLED, A MINIMUM 3' RADIUS IS REQUIRED.



RESIDENTIAL BITUMINOUS DRIVEWAY ENTRANCES WITHOUT CURBS

REVISED: 2-24

ENGINEERING DEPARTMENT

PLATE NO.:

5209B