



Chanhassen Fire Department

FIRE PREVENTION BUREAU

7700 Market Blvd. PO Box 147

Chanhassen, MN 55317

Ph. 952.227.1150 Fx. 952.227.1190

CHANHASSEN FIRE DEPARTMENT POLICY DOOR SIGNAGE

Required signage for the following doors and exit corridors:

1. Doors to electrical rooms:
 “Electrical Room
 No Storage Allowed
 By order of the Fire Marshal”
2. Doors to Mechanical Rooms:
 “Mechanical Room
 No Storage Allowed
 By order of the Fire Marshal”
3. Back exit doors: Interior and Exterior
 “Emergency Exit Door
 Do Not Block
 By order of the Fire Marshal”
4. Doors to rooms with no interior access
 shall read:
 “No Interior Access”
5. A 704 Hazard Placard will be required if bulk CO2 is stored/used.

 Contact Fire Marshal for details:
 952-227-1151

4. **Note** – Rooms that have multiple uses may be required to have additional signage, e.g. **Electrical Room, Fire Sprinkler Control Valves, Roof Access, and Mechanical Room.** The Fire Marshal will determine the appropriate language.

5. Letters must be a minimum of “2” high and of contrasting color to the background. Any deviation of lettering must have Fire Marshal approval.

6. Additional signage may be required in the following areas. Walls in exit paths, corridors and stairs will be required to have the following wording on the sign; **“Emergency Exit - No storage allowed in this area by order of the Chanhassen Fire Marshal”**. Placement of the signs will be determined by the Fire Marshal and installed prior to receiving the certificate of occupancy.

Revisions 6/12/04, 3/24/05, 5/2/08, 2/15/10, 4/17/17