



Chanhassen Fire Department

FIRE PREVENTION BUREAU

7700 Market Blvd. PO Box 147
Chanhassen, MN 55317


Ph. 952.227.1150 Fx. 952.227.1190

CLASS I-IV COMMODITIES ONLY

IFC Chapter 23 as amended

FOR

Buildings capable of storing high-piled combustible stock,
but not intended to be used for such purpose over **12** feet.



1. Striping shall be continuous around the interior perimeter of the area used for storage.
2. Wording **"No stacking above this line by order of CFD"** shall be placed every fifty (50) linear feet of striping.