



PUBLIC STREET

CITY WATER HYDRANT

MANHOLE

12'-0" MIN BIT DRIVEWAY

LIFT STATION

VALVE MANHOLE

FORCEMAIN

CONTROL PANEL

TRANSFORMER

40'-0"

25'-0"

15'-0"

30'-0"

NTS

10'-0" MIN

GENERAL NOTES

1. A MINIMUM OF ONE (1) SOIL BORING AND ACCOMPANYING GEOTECHNICAL REPORT IS REQUIRED IN VICINITY OF LIFT STATION
2. COORDINATE ELECTRICAL POWER SERVICE WITH UTILITY

FILE NAME: G:\ENG\SPEC\5402C
ENGINEERING DEPARTMENT
REVISED: 1-22
PLATE: 5402-C
LIFT STATION AND VALVE SITE DETAIL
 CITY OF CHATHAM